



NOTES:

- 1. SLOPE INVERT OF MANHOLE AS INDICATED ON PLAN-PROFILE SHEET.
- 2. LAYERS OF REINFORCING STEEL NEAREST THE INTERIOR AND EXTERIOR SURFACE SHALL HAVE A COVER OF 2" TO THE CENTER OF BARS, UNLESS OTHERWISE NOTED.
- 3. CONCRETE SHALL BE CLASS "A".

Wichita Falls TEXAS	DEC 03				6100B-00				CITY OF WICHITA FALLS, TX
	DATE DRAWN				STANDARD DRAWING NO.				STORMWATER MANHOLE 4', 5', OR 6' SQUARE
									APPROVED
StormMH-4to6ftSq-2	NO.	DATE		DES	CRIPT	ION		BY	Keffens Aft yan, P.E. DEC 2003
ACAD DRAWING NAME	R	Ε	٧	I S	ı	0	N	s (CITY ENGINEER DATE

DISCLAIMER: The use of this standard is governed by the City of Wichita Falls Engineering Department. No warranty of any kind is nade by the City of Wichita Falls for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the conversion of this standard to other formats for incorrect results or damages resulting from its use.